

फ़ोन/Ph: +91-33-24014132-36

फैक्स/Fax: +91-33-24010553

वेबसाइट/Website: <http://igmkolkata.spmcil.com>

ई-मेल/E-mail: calmint@spmCIL.com



भारत सरकार टकसाल
INDIAGOVERNMENTMINT

(भारत प्रतिभूति मुद्रण तथा मुद्रा निर्माण निगम लिमिटेड की एक इकाई)
(A Unit of Security Printing and Minting Corporation of India Limited)
(मिनिरत्न, श्रेणी-I सीपीएसई / A Mini Ratna, Category-I CPSE)



आईएसओ 9001:2008 एवं 14001:2004 प्रमाणित कंपनी / An ISO 9001:2008 & ISO 14001:2004 Certified Company

भारत सरकार के पूर्ण स्वामित्वाधीन / Wholly Owned by Government of India

अलीपुर / Alipore, कोलकाता / Kolkata - 700 053

Corporate Identity Number (CIN): U22213DL2006GOI144763

No. 54/T-58(24-25)/GEM/2024/B/5020253/Corrigendum-I

Date: 12.07.2024

To,

The Bidders

Reference Tender Document No. 54/T-58(24-25)/GEM/2024/B/5020253 Dated: 13.06.2024

Subject : SITC OF MICROPROCESSOR BASED FIRE ALARM SYSTEM IN ADMIN BUILDING OF INDIA GOVERNMENT MINT KOLKATA

Corrigendum -I

Sir/Madam,

With reference to above, the following amendment in Bid document may please be noted:

1. In Specification Document following point has been Amended:

Clause no./details of Technical Specifications	Description	Earlier in bid document	Read as
2	SITC of Digital Amplifiers	SITC of Digital Amplifiers having 100W, 70.7 VRMS, Multi-Channel, Multi-Circuit Digital Amplifiers. The amplifiers shall be of same make as that of the control panel. Amplifiers shall be fully supervised and shall have same battery and power backup as that of the control panel. There should be 1No. of Back-up amplifier (1:N) for the entire amplifiers. In case any Amplifier fails alternate backup amplifier has to take-over. Make- Zettler/Fireclass/Simplex/Notifire/Edwards or equivalent.	SITC of Digital Amplifiers having 100W or above power rating, 70.7 VRMS or above voltage rating, Multi-Channel, Multi-Circuit Digital Amplifiers or Single Channel Multi Circuit Digital Amplifiers. The amplifiers shall be of same make as that of the control panel. Amplifiers shall be fully supervised and shall have same battery and power backup as that of the control panel. There should be 1No. of Back-up amplifier (1:N) for the entire amplifiers. In case any Amplifier fails alternate backup amplifier has to take-over. Make- Zettler/Fireclass/Simplex/Notifire/Edwards or equivalent
12	SITC of Short Circuit Isolator	SITC of Intelligent Addressable, Supervised Short-Circuit Isolator module or base. The Isolator Monitor Module shall have operating temperature range from 0°C to 49°C and a humidity tolerance of up to 90% RH, Non- Condensing. Make- Zettler/Fireclass/Simplex/Notifire/Edwards or equivalent.	SITC of Intelligent Addressable, Supervised Short-Circuit Isolator module or base / SITC of Intelligent Addressable in-built isolator detectors and modules but the same must be UL listed and FM approved. The Isolator Monitor Module shall have operating temperature range from 0°C to 49°C and a humidity tolerance of up to 90% RH, Non- Condensing. Make- Zettler/Fireclass/Simplex/Notifire/Edwards or equivalent.
22	SITC of 4x4 PVC BOX	Supply & Installation of 4*4 PVC Box. Make- Finolex/Utkarsh/AKG/BEC or equivalent.	Supply & Installation of 4*4 PVC Box or Metal Box. Make- Finolex/Utkarsh/AKG/BEC or equivalent.

फोन/Ph: +91-33-24014132-36

फैक्स/Fax: +91-33-24010553

वेबसाइट/Website: <http://igmkolkata.spmcil.com>

ई-मेल/E-mail: calmint@spmCIL.com



भारत सरकार टकसाल

INDIAGOVERNMENTMINT

(भारत प्रतिभूति मुद्रण तथा मुद्रा निर्माण निगम लिमिटेड की एक इकाई)

(A Unit of Security Printing and Minting Corporation of India Limited)

(मिनिरत्न, श्रेणी-I सीपीएसई / A Mini Ratna, Category-I CPSE)

आईएसओ 9001:2008 एवं 14001:2004 प्रमाणित कंपनी / An ISO 9001:2008 & ISO 14001:2004 Certified Company

भारत सरकार के पूर्ण स्वामित्वाधीन / Wholly Owned by Government of India

अलीपुर / Alipore, कोलकाता / Kolkata - 700 053

Corporate Identity Number (CIN): U22213DL2006GOI144763



2. Accordingly last date of submission of the tender through GeM portal is extended as below:

Bid Document Lines	Earlier		Read As	
Bid End Date/Time	13.07.2024	15:00:00	26.07.2024	15:00:00
Bid Opening Date/Time	13.07.2024	15:30:00	26.07.2024	15:30:00

All other terms & conditions of the subjected tender will remain unchanged.

This is issued with the approval of Competent Authority.

Yours faithfully,

Jt. GM (TO) & MATERIALS HEAD
For Chief General Manager