

फोन/Ph: +91-33-24014132-36

फैक्स/Fax: +91-33-24010553

वेबसाइट/Website: <http://igmkolkata.spmcil.com>

ई-मेल/E-mail: calmint@spmcil.com



भारत सरकार टकसाल
INDIAGOVERNMENTMINT

(भारत प्रतिभूति मुद्रण तथा मुद्रा निर्माण निगम लिमिटेड की एक इकाई)
(A Unit of Security Printing and Minting Corporation of India Limited)
(मिनिरत्न, श्रेणी-I सीपीएसई / A Mini Ratna, Category-I CPSE)



आईएसओ 9001:2008 एवं 14001:2004 प्रमाणित कंपनी / An ISO 9001:2008 & ISO 14001:2004 Certified Company

भारत सरकार के पूर्ण स्वामित्वाधीन / Wholly Owned by Government of India

अलीपुर / Alipore, कोलकाता / Kolkata - 700 053

Corporate Identity Number (CIN): U22213DL2006GOI144763

No. 54/T-56(24-25)/GEM/2024/B/4992668/Corrigendum-II

Date: 11.07.2024

To,
The Bidders

Reference Tender Document No. 54/T-56(24-25)/GEM/2024/B/4992668 Dated: 07.06.2024

Subject : SITC OF MICROPROCESSOR BASED FIRE ALARM SYSTEM IN FACTORY OF INDIA GOVERNMENT MINT KOLKATA

Corrigendum -II

Sir/Madam,

With reference to above, the following amendment in Bid document may please be noted:

1. In Specification Document following point has been Amended:

Clause no./details of Technical Specifications	Description	Earlier in bid document	Read as
12	SITC of Short Circuit Isolator	SITC of Intelligent Addressable, Supervised Short-Circuit Isolator module or base. The Isolator Monitor Module shall have operating temperature range from 0°C to 49°C and a humidity tolerance of up to 90% RH, Non- Condensing.	SITC of Intelligent Addressable, Supervised Short-Circuit Isolator module or base. The Isolator Monitor Module shall have operating temperature range from 0°C to 49°C and a humidity tolerance of up to 90% RH, Non-Condensing. The supplier may provide in-built isolator detectors and modules, but, the same must be UL listed and FM approved.
14	SITC of Fire fighter telephone station	SITC of Fire Fighter Telephone Station complete with Fire Fighter's Handset and Accessories enclosed in a Red Enclosure. The fire fighter's handset should be of the same make as the fire alarm system or equivalent. Qty: 05 nos.	SITC of Fire Fighter Telephone Station complete with Fire Fighter's Handset and Accessories enclosed in a Red Enclosure. The fire fighter's handset should be of the same make as the fire alarm system or equivalent. Qty: 12 nos. Note: There shall be 1 no. master telephone handset and it should be integrated inside the main fire alarm panel.
----	The following points are added in the tender document:	-----	The Contract Awarded firm has to provide the following: 1. Document depicting sequence of operation 2. Floor plan with device location 3. Equipment data sheet 4. Operation & Maintenance Manual 5. Electrical and electronic diagram 6. Drawing of the installed system 7. Copy of the site-specific software including instructions on how to get access of the system by entering provided password (software should not be locked i.e. it should be usable for entire life-span period of the Fire Alarm system) 8. The firm shall submit a declaration for the availability of spares & consumables of the entire system for the next 10 years

फोन/Ph: +91-33-24014132-36

फैक्स/Fax: +91-33-24010553

वेबसाइट/Website: <http://igmkolkata.spmcil.com>

ई-मेल/E-mail: calmint@spmCIL.com



भारत सरकार टकसाल
INDIAGOVERNMENTMINT

(भारत प्रतिभूति मुद्रण तथा मुद्रा निर्माण निगम लिमिटेड की एक इकाई)
(A Unit of Security Printing and Minting Corporation of India Limited)
(मिनिरल, श्रेणी-I सीपीएसई / A Mini Ratna, Category-I CPSE)



आईएसओ 9001:2008 एवं 14001:2004 प्रमाणित कंपनी / An ISO 9001:2008 & ISO 14001:2004 Certified Company

भारत सरकार के पूर्ण स्वामित्वाधीन / Wholly Owned by Government of India

अलीपुर / Alipore, कोलकाता / Kolkata - 700 053

Corporate Identity Number (CIN): U22213DL2006GOI144763

2. Accordingly last date of submission of the tender through GeM portal is extended as below:

Bid Document Lines	Earlier		Read As	
Bid End Date/Time	28.06.2024	15:00:00	25.07.2024	15:00:00
Bid Opening Date/Time	28.06.2024	15:30:00	25.07.2024	15:30:00

All other terms & conditions of the subjected tender will remain unchanged.

This is issued with the approval of Competent Authority.

Yours faithfully,

Jt. GM (TO) & MATERIALS HEAD
For Chief General Manager